City of Carmel Utilities

3450 W. 131st. Street
Carmel, In. 46074

317-733-2855
Fax: 317-733-2053

CITY of CARMEL WATER DISTRIBUTION
11/2" – 2" INSIDE METER SETS

1. All new commercial buildings are required Back flow Devices.
2. All new businesses relocating in existing commercial buildings are required backflow devices within 30 days.
3. Devices shall be of the type approved by Indiana Department of Environmental Management.
4. Depending on the degree of hazard, the Water Distribution Department will decide if you need a Double Check or a Reduced Pressure backflow device.
5. The device must be tested at the time of installation by a State Certified Backflow tester and at the correct intervals for the type of device.
6. Test results are to be sent to: Carmel Water 3450 W 131ST ST, Carmel, IN. 46074

A: Angle Meter Stop.	(Legend Valve) or Comparable Model T-1001 Full Port Ball Valve 11/2" – 2"
B: Flanged Coupling	(Ford) CF-31-66 11/2" (Ford) CF- 31-77 2"
C: Distance for Meters.	11/2" Meter = 13 ¼" 2" Meter = 17 ¼"



A.

B.



Carmel Utilities

Specification for a 1 1/2" or