



NOTE:

- 1) 1" Or Smaller Service Line Shall Be Direct Tap Unless Approved By Carmel Utilities.
- 2) Corporation Stop Shall Be Brand And Model Approved By Carmel Utilities.
- 3) Service Line Tap Shall Be Installed With A Min. Horiz. Separation of 24".
- 4) 2 Inch Taps And Smaller Shall Not Be Installed Within 18 Inches of Mechanical Joints And Bells.

* Service Saddle Must Be Omitted For Services 1" And Smaller And Direct Taps Made to Ductile Iron Pipe, Class 350 Or Greater. (Verify With Owner For Pressure Class DIP.)

** For all Service Lines Installed Under Pavement Install HDPE Sleeve Under Pavement Section.

<p>CITY OF CARMEL STANDARD DETAILS</p>		<p>TITLE: COMMERCIAL WATER SERVICE DETAIL</p>	
<p>DATE: MARCH 2007</p>	<p>SCALE: NOT TO SCALE</p>	<p>DRAWN BY: CROSSROAD ENGINEERS, PC</p>	<p>DRAWING NAME: CW4-1</p>